


Missouri
Department
of Transportation



Roger Schwartz, District Engineer

Central District
1511 Missouri Boulevard
P.O. Box 718
Jefferson City, MO 65102
(573) 751-3322
fax (573) 522-1059
Toll free 1-888 ASK MoDOT
www.modot.org

September 20, 2007

RE: Addendum 02 to Bid D5-08-009Q, Fuel Cabinets (Wayne G6205P/2GJK Twin I HS)

Dear Vendors:

Please note that this letter is to inform all potential bidders of a second addendum to Bid D5-08-009Q. The changes to this addendum are as follows:

Item 1, Page 1, second bullet point: Regarding O.P.W automatic shutoff nozzle, MoDOT will be purchasing a quantity of one diesel fuel cabinet and a quantity of one unleaded fuel cabinet.

Item 2, Page 2, first bullet point: The requirement for a hose mast shall be removed and offered as an option in lieu of the internal hose retractor. As it reads currently, I a host mast and a hose retractor cannot be used at the same time.

Item 3, Page 2, Option pricing I): Please quote as a per section price. 25' for a 1" ID Diesel fuel hose and 20' for a 3/4" ID Regular fuel hose. If quoting different, please indicate.

Item 4, Page 2, Option pricing K): Installation price shall include setting the cabinet on a concrete slab, hooking up to existing wiring and piping, perform start-up and purge and test system for fuel dispensing. Piping and wiring will be installed by an outside contractor prior to installation of the fuel cabinets.

Bid opening date remains for September 24, 2007 at 1:00 pm.

If you have any questions, please call.

Thank you!

Corey Duemmel
D5 General Services
(573) 526-6956